CERAMIC TILES - TEST REPORT

(SLIP RESISTANCE BY RAMP TEST)

DATE OF TESTING : 26/06/2026

REPORT OF TEST ON : Slip Resistance of Surface of Tiles
TEST DESCRIPTION : Slip Resistance by Ramp Test (DIN 51130)
TEST INSTRUMENT : Ramp Tester by Ceramic Instruments, Italy
RUBBER SHOES SOLE: 4'S

SAMPLE DESCRIPTIONS: (MORANO MOCHA)

Model	:	AG00PARS-073.Z1U	**Type of product**	:	Gres Porcellanato Tile
Nominal size	:	30 x 30 cm.	**Nature of surface**	:	Unglazed/Unpolished
Caliber no.	:	A3	**Group**	:	BIa
Thickness	:	8.5 mm	**Origin of specimen**	:	From MC-2

SURFACE CONDITION: Cleaned / Oil Wet Condition / Shod Method

OPERATOR NO.	CRITICAL ANGLE VALUE	MEAN CRITICAL ANGLE VALUE	SLIP RESISTANCE 'R' CLASIFICATION
1	24.9°	25.1°	R11
2	25.1°		

CLASSIFICATION:

CRITICAL ANGLE VALUE	CATEGORY	'R' CLASSIFICATION
6° to 10°	Low	R9
>10 to 19°	Normal	R10
>19° to 27°	Above average	R11
>27° to 35°	High	R12
>35°	Very high	R13

SLIP RESISTANCE ASSESSMENT GROUP: R11

Test performed by:

ROMMEL CANTOLLAS
Name & Signature
Laboratory Technician

RAK CERAMICS PJSC
P.O. Box 4714
Ras Al Khaimah
U.A.E.

RAK Ceramics PJSC
P.O. Box 4714
Ras Al Khaimah
United Arab Emirates

Tel. +971 7 246 7000
Fax. +971 7 244 5270

RAKCERAMICS.COM